

REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal American School, Verowal Road, VPO Dharar, Jandiala Guru, Amritsar
American School, Verowal Road, VPO Dharar, Jandiala Guru, Amritsar


No.: RWTLASR/2526/00026 Dated : 25/04/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. ASR/DR/JDL/25-26/05 Dated: 16/04/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 16/04/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar



TC-13602

TEST REPORT

Name & Address of Customer : Principal American School, Verowal Road, VPO Dharar, Jandiala Guru, Amritsar American School, Verowal Road, VPO Dharar, Jandiala Guru, Amritsar		Customer Reference No. No : ASR/DR/JDL/25-26/05 Dated : 16/04/2025
		Sample Submitted by Mr. Ashok Mahajan
		Date of Sample Receipt 16/04/2025
		Analysis Starting Date 16/04/2025
		Analysis completion Date 17/04/2025
Discipline : Chemical Testing		Group: Water
ULR No.:	TC136022500000259F	Sample Type : Water
Test Report No.:	RWTLASR/2526/00026	Date of Issue : 25/04/2025
Registration no.:	RWTLASR/REG2526/00208	Condition of Sample : Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle: 1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth : Verowal Road(S/pump 300 ft) / NA
Village :	Not Mentioned	Habitation : Not Mentioned
Block:	Not Mentioned	District : Amritsar
Latitude :	Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.64@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	270	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.10@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity[CaCO ₃]	260	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness[CaCO ₃]	228	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium[Ca]	48.09	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium[Mg]	26.24	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride[Cl]	25.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Amritsar

----- End of the Test Report -----

Civil Surgeon Office Tarn Taran

No.CSTT San/2025/580

Date: 2/6/2025

To Whom It May Concern

This is to certify that we have inspected American School Dharwar
Jandiala Gurus . After inspecting their Toilets,

and other rooms, we can certify that their Cleanliness and sanitation is good. Their water is Potable through RO system as per report of Rural Water Supply and Sanitation Department. This certificate is valid for one year from the date of issue. No Health Hazard is seen in the premises of the school. There are separate washroom for girls and boys.


District Epidemiologist
Tarn Taran